

Appendix F6

KSM Transmission Line: Preliminary Geotechnical Review



SEABRIDGE GOLD INC.

KSM PROJECT

TEIGEN CREEK - KSM TRANSMISSION LINE: PRELIMINARY GEOTECHNICAL REVIEW

DRAFT

PROJECT NO: 0638-005 DATE: February 7, 2012 DOCUMENT NO:

DISTRIBUTION: RECIPIENT: 2 copies BGC: 2 copies WN BRAZIER: 1 copy

R.2.7.5.3



Fax: 604.684.5909

February 7, 2012 Project No: 0638-005

Brent Murphy, M.Sc., P.Geo. Seabridge Gold Inc. 106 Front Street East Toronto, Ontario, M5A 1E1

Dear Mr. Murphy,

Re: <u>KSM Project Teigen Creek - KSM Transmission Line: Preliminary Geotechnical</u> <u>Review</u>

Please find attached a copy of the above referenced report dated February 7, 2012.

Should you have any questions or comments, please do not hesitate to contact the undersigned. We appreciate having the opportunity to continue working on such an interesting and challenging project

Yours sincerely,

BGC ENGINEERING INC. per:

Kris Holm, M.Sc., P.Geo Project Manager

TABLE OF CONTENTS

TABLI	E OF CONTENTSi
LIST C	OF APPENDICES ii
LIST C	OF DRAWINGSii
LIMIT	ATIONS iii
1.0	INTRODUCTION1
1.1.	Scope of Work1
1.2.	Work Procedure1
2.0	SITE AND TRANSMISSION LINE DESCRIPTION
2.1.	Transmission Line Alignment2
2.2.	Climate, Geology, and Geomorphic Setting2
2.3.	Transmission Tower Structures3
3.0	PRELIMINARY GEOTECHINICAL ASSESSMENT
3.1.	Compilation of Existing Geotechnical Data
3.2.	Transmission Line Field Reconnaissance Review4
4.0	DISCUSSION
4.1.	Preliminary Geotechnical Comment4
4.	.1.1. Transmission Line Alignment Route
	.1.2. Transmission Line and Access Road Design Integration
	1.3. Snow Avalanche Foundation Structures
	.1.4. Foundation Types
	Conceptual Geohazard Mitigation Structures Designs
	2.1. Snow Avalanches
	.2.2. Debris Floods / Debris Flows
4.3.	j
	RECOMMENDATIONS FOR FURTHER WORK
	CLOSURE
REFE	RENCES

N:\BGC\Projects\0638 Seabridge\005 KSM Geohazards\05 - Reporting\Report\KSM Teigen Creek Transmission Line Prelim Geotech Assessment\20120207 KSM transmission line_preliminary geotechnical review.docx Page i

LIST OF APPENDICES

- APPENDIX A AVALANCHE AREA FOUNDATION TYPE AP-1
- APPENDIX B TOWER SITE GEOLOGIC AND GEOHAZARD CHARACTERIZATION SUMMARY
- APPENDIX C PRELIMINARY GEOTECHNICAL COMMENTS

LIST OF DRAWINGS

- DRAWING 01 TEIGEN ACCESS ROAD AND TRANSMISSION LINE TERRAIN MAP AND LANDSLIDE GEOHAZARDS
- DRAWING 02 TEIGEN ACCESS ROAD AND TRANSMISSION LINE AVALANCHE GEOHAZARDS
- DRAWING 03 TEIGEN ACCESS ROAD AND TRANSMISSION LINE SLOPE CLASS MAP

N:\BGC\Projects\0638 Seabridge\005 KSM Geohazards\05 - Reporting\Report\KSM Teigen Creek Transmission Line Prelim Geotech Assessment\20120207 KSM transmission line_preliminary geotechnical review.docx Page ii

LIMITATIONS

BGC Engineering Inc. (BGC) prepared this document for the account of Seabridge Gold Inc.. The material in it reflects the judgment of BGC staff in light of the information available to BGC at the time of document preparation. Any use which a third party makes of this document or any reliance on decisions to be based on it is the responsibility of such third parties. BGC accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this document.

As a mutual protection to our client, the public, and ourselves, all documents and drawings are submitted for the confidential information of our client for a specific project. Authorization for any use and/or publication of this document or any data, statements, conclusions or abstracts from or regarding our documents and drawings, through any form of print or electronic media, including without limitation, posting or reproduction of same on any website, is reserved pending BGC's written approval. If this document is issued in an electronic format, an original paper copy is on file at BGC and that copy is the primary reference with precedence over any electronic copy of the document, or any extracts from our documents published by others.

1.0 INTRODUCTION

BGC Engineering Inc. (BGC) was retained by Seabridge Gold Inc. (Seabridge) to assess geohazard risks for the Kerr-Sulphurets-Mitchell (KSM) project in northwestern British Columbia. In earlier stages of geohazard risk assessment for the KSM project, BGC completed a geohazard and risk assessment for the KSM mine-site, tailings management facility, and access roads for the project areas (BGC, 2011) as well as a terrain stability field assessment (TSFA) for KSM mine access roads including the Teigen Creek access road (BGC, 2010). Earlier work did not include geotechnical assessment of the transmission line alignment. As an extension of the earlier work, BGC was requested by Seabridge in an April 18, 2011 email to review available data for the proposed Teigen Creek – KSM 287 kV transmission line from Snowbank Creek to KSM substation #1 and comment on potential geotechnical constraints for the transmission line.

This memorandum provides preliminary geotechnical assessment of the Teigen Creek - KSM transmission line alignment and provides geotechnical comments on the conceptual design for reinforced concrete tower foundations proposed for sites subject to geohazards. No detailed subsurface investigations of soil and rock conditions, groundwater conditions, or material testing were carried out as part of this work.

Routing and design for the transmission line is being led by W.N. Brazier and Associates Inc. (WN Brazier). Routing and design of the access road is being led by McElhanney Consulting Services Ltd. (McElhanney).

1.1. Scope of Work

The following work was completed for this report:

- Summarizing available terrain and geohazard information with respect to the current transmission line alignment, considering proximity to the access road alignment, planned road-cut and fill slope locations, terrain assessment units, geologic units, and slope angles at tower sites.
- Supplementing geotechnical observations from previous BGC terrain and geohazard risk assessments by completing a field assessment of the transmission line including hand-held GPS guided helicopter fly-over and ground traverse of key locations. This was completed in conjunction with WN Brazier between September 12 and 15, 2011.
- Summarizing preliminary geotechnical comments on the transmission line alignment.
- Evaluating conceptual designs for reinforced concrete foundations prepared by WN Brazier for areas subject to geohazards.

1.2. Work Procedure

The work procedure followed in this assessment used terrain and geohazard mapping from previous BGC work (BGC 2010, 2011) combined with an initial transmission line alignment (Rev 2, dated September 2, 2011) by WN Brazier to make an office based assessment of anticipated geotechnical and geohazard conditions at tower sites. This work was used to

prioritize sites for field assessment that was completed jointly with WN Brazier. The field assessment resulted in an adjusted alignment (Rev D, dated October 2011) by WN Brazier that avoids some identified geohazards or undesirable geotechnical conditions reviewed in the field.

The adjusted Rev D, October 2011, alignment is documented in this report. Other proposed project facilities incorporated in drawings are based on the June 14, 2011 KSM project facility layout assessed in BGC (2011). LiDAR topography and ortho-images collected in 2009 and sourced from McElhanney were used as base map information for the transmission line study area.

2.0 SITE AND TRANSMISSION LINE DESCRIPTION

2.1. Transmission Line Alignment

The proposed Teigen Creek - KSM transmission line is routed to closely follow the Teigen Creek access road. The proposed transmission line is 12 km long and would connect with BC Hydro's planned 287 kV Northwest Transmission Line at Snowbank Creek on Highway 37. Following a crossing of Highway 37, the transmission line generally parallels the proposed Teigen Creek access road ascending southward along the west (left) side of Teigen Creek until transmission line chainage km 3. The alignment then crosses to the east (right) side of Teigen Creek and continues towards transmission line chainage km 8 where the line again crosses to the west (left) side of Teigen Creek. Continuing south, the transmission line parallels the southern Teigen Creek tributary and ascends gently sloping (3° to 15°) terrain terminating at KSM Substation #1 near the proposed plant site area at transmission line chainage km 12.

2.2. Climate, Geology, and Geomorphic Setting

The TSFA report (BGC, 2010) and the preliminary geohazard report (BGC, 2011) provide a description of climate, geology and geomorphic setting within the study area.

In summary, the KSM property encompasses temperate or northern coastal rainforest in the coastal mountains of northwest BC, with subarctic conditions at high elevations. Elevations range from 550 masl where Teigen Creek intersects Highway 37 to over 2,300 masl at the nearby highest peaks. The Teigen Creek valley is a broad, steep-sided basin with forested lower valley slopes. The valley bottom floor contains a 50 to 400 m wide floodplain with organic and fluvial deposits. Lower valley slopes are typically underlain by colluvium and glacial till with some discontinuous segments of the lower valley underlain by remnant depositional glaciofluvial terraces. Debris flow fans extend across the proposed access road and transmission line alignment at 4 locations. Mid to upper valley slopes consist of gullied bedrock partially covered in thin (< 1 m) colluvium or glacial till. A glacially scoured bedrock plateau with organic deposits infilling shallow depressed lineaments is present at the southern end of the transmission line alignment, near the proposed plant site. Teigen Creek

valley and the glacially scoured bedrock plateau are underlain by interbedded sandstones and siltstones of the Bowser Lake Group.

2.3. Transmission Tower Structures

WN Brazier proposes steel (un-guyed) monopole structures with multi-pole structures considered for dead-end pole structures for the alignment.

In areas subjected to avalanches, WN Brazier proposes a steel (unguyed) monopole structure fixed atop a concrete pier with an adjacent steel deflector post facing into the direction of the avalanche path and with ground anchors grouted into rock or solid below (see Appendix A). The height of the concrete pier would be dependent on the magnitude of the avalanche hazard. The steel deflector post would be designed to protect against less dense avalanche snow flows. The lower concrete pier would be designed to protect against dense snow and general debris impacts (mud and rock).

Tower foundation design loads and foundation performance criteria have not been detailed for this design stage.

3.0 PRELIMINARY GEOTECHINICAL ASSESSMENT

3.1. Compilation of Existing Geotechnical Data

Drawings 1 and 2 show the current Rev D, October 2011 transmission line alignment combined with terrain mapping, landslide and snow avalanche geohazards mapped in BGC (2011). Drawing 3 outlines different slope classes for the study area using 2009 LiDAR obtained from McElhanney and Geobase topography where LiDAR is not available. Adjectives used to describe ranges of slope classes include:

- Plain slopes: 0 to 3° (0 to 5%)
- Gentle slopes: 3 to 15° (6 to 26%)
- Moderate slopes: 15 to 26° (27 to 49%)
- Moderately Steep slopes: 26 to 35° (50 to 70%)
- Steep slopes: 35 to 45° (71 to 100%)
- Very Steep slopes: >45° (>100%)

Table B-1 in Appendix B summarizes terrain and geohazard conditions at each proposed tower site for the October 2011 Rev D alignment. This includes terrain and geologic units, natural slope gradients, proximity of tower sites to planned access road-cut or fill slope, and the potential for snow avalanche or landslide geohazards. Where towers intersect geohazard areas, Table B-1 shows geohazard risk levels estimated by BGC (2011) and identifies tower sites where WN Brazier proposes reinforced concrete tower foundations to mitigate against snow avalanche hazard. BGC (2011) provides more detailed descriptions of terrain stability mapping and geohazard nomenclature referred to in Table B-1.

3.2. Transmission Line Field Reconnaissance Review

Helicopter and ground based field geotechnical assessments of tower sites were carried out by Mr. Greg Hunchuk P.Eng., P.Geo., and Mr. Philip LeSueur, E.I.T. of BGC between September 12 and 15, 2011. BGC personnel were accompanied by the transmission line lead designer, Mr. Neil Brazier, P.Eng., of WN Brazier.

The entire length of the Rev 2, September 2, 2011 transmission line alignment was inspected by helicopter, and 25 of 56 tower sites were inspected on the ground (see Table B-1). Ground-based assessments included characterization of terrain and soil conditions based on surface mapping and by shallow hand-dug test pits.

BGC's selection criteria for ground based inspection sites was based upon general requirements to visit representative terrains covering the transmission line alignment and to visit specific tower sites located on terrains with attributes suggesting potentially challenging design and / or construction conditions. Tower sites that were selected for ground-based field inspection included those:

- located within terrain showing evidence of slope instability;
- located on steeper slopes or adjacent to slope breaks;
- situated on poorly drained sites;
- located on active debris flow fans; and / or
- obscured by heavy vegetation.

Following the field assessment and considering desk study and field observations by BGC and WN Brazier, WN Brazier provided an update to the Teigen Creek - KSM Transmission Line, Rev. D alignment dated October 2011 as discussed in Section 1.2. Additional geohazard and terrain observations from the field inspection are included in Table B-1.

4.0 DISCUSSION

4.1. Preliminary Geotechnical Comment

A summary of preliminary geotechnical comments for the Teigen Creek – KSM transmission line is provided in Table C-1 in Appendix C. The current Rev D, October 2011 alignment is the basis for Table C-1.

4.1.1. Transmission Line Alignment Route

No geotechnically unfavorable ground conditions were identified that would preclude construction of the Teigen Creek – KSM transmission line.

Suggested tower structure location adjustments are described in Table B-1 for structures TP21-1, TP25-1 to TP27-1, TP34-1, TP35A-1, and TP40-2 with respect to the Rev D alignment. These suggested adjustments would move structures onto flatter sloping terrain or further away from stream channels. The most significant line alignment deviation suggested is related to tower structures TP25-1, TP26-1, and TP27-1 which are located on Moderately Steep to Steep slopes within inferred deeper soils. Special foundations such as

micropiles, (discussed in Section 4.1.4) may be required if the tower structures are maintained in their present position. An alternative option to constructing special foundations for these sites would be to adjust the transmission line alignment and locate towers approximately 80 m upslope (east) of the present alignment on Gentle to Moderate slopes.

Near tower structures TP 35-1 and TP36-1 (between KP 8.8 and KP 9.7 of the access road), McElhanney and WN Brazier could consider re-aligning the Teigen Creek Access Road and associated towers approximately 10 m to 15 m west. Adjusting the road and transmission line alignments in this section would allow tower structures along the road edge to maintain a greater set-back from the Moderately Steep to Steep slope break located immediately adjacent thereby reducing the potential for any future slope retrogression to impact the structure locations.

4.1.2. Transmission Line and Access Road Design Integration

For the majority of the Teigen Creek - KSM Transmission Line alignment, tower structures are located upslope of the Teigen Creek Access Road. Review and integration of tower structure and access road design will be required in locations where tower structures are located in close proximity to steeper access road cut slopes. Towers located adjacent to access road cuts situated on Moderately Steep to Steep slopes include tower structures TP12-1, TP23-1 to TP29-1, and TP34-1.

Access road drainage structures, such as culverts and ditches, can divert and concentrate surface water flows downslope. Review and integration of access road and transmission line design will be required where tower structures are located downslope of access roads and there is the potential to direct surface waters from the access road to near transmission tower locations. Tower structures located downslope of the access road include TP3-1 to TP6-1, TP35-1 to TP36-1, and TP37-1 to TP40-2. Similarly, equipment access trails for tower construction will need to be deactivated to reduce their potential for surface water redirection.

4.1.3. Snow Avalanche Foundation Structures

With respect to the Rev D alignment, snow avalanche foundation structures are proposed by WN Brazier for tower sites TP4-2, TP6-1 to TP8-1, TP10-1, TP13-1 to TP18-1, TP20-1 to TP23-1, TP29-1, and TP30-1 as summarized in Table B-1.

We note that WN Brazier identified snow avalanche foundations for tower structures TP8-1 and TP10-1 but BGC (2011) did not map these towers as being located within snow avalanche hazard areas. Conversely, tower structures TP4-1, TP19-1, and TP24-1 to TP27-1 are in areas mapped as snow avalanche hazard by BGC (2011), but are not identified within the Rev D alignment as tower sites requiring snow avalanche foundations. In the next stage of study, field review of tower sites in mapped avalanche areas by an avalanche expert and numerical modeling to estimate impact pressures will be necessary to confirm avalanche potential and effects at each tower site.

4.1.4. Foundation Types

Foundation and topographic conditions in combination with design loading conditions, foundation performance requirements, the construction schedule, and available construction access will affect the type of tower foundation design selected and construction method for individual tower sites.

Preliminary geotechnical comments regarding potential foundation types for sections along the transmission line alignment are provided in Table C-1. As discussed in Section 4.3, subsurface investigations are necessary as part of prescribing specific foundation types for each tower location. Subject to the pole structure type at each location, at this design stage the following foundation types can be considered to cover the range of terrain conditions that have been observed along the transmission line alignment:

- Concrete spread footing, including being a massive buried block
- Drilled caissons
- Rock anchor foundations
- Special foundation driven piles
- Special foundations micropiles

Concrete spread footing or drilled caissons:

These foundation types are a potential option for sites with sufficient soil depth and soil strength to allow sufficient burial for lateral restraint and sufficient bearing capacity and adequate settlement. These will typically be in compact granular soils or stiffer cohesive soils.

Rock anchor foundations:

This foundation type is considered a potential option for sites where surficial soils are too shallow to provide a minimum foundation embedment depth for concrete spread footings or drilled caissons.

Special foundations - driven piles:

This foundation type is considered a potential option for sites comprised of low bearing capacity near surface soils and where it is not practical to construct stable excavations to reach an adequate bearing stratum at depth or to install a concrete foundation or caisson to have adequate lateral stability. Driven piles of sufficient length and diameter would bridge into soils with sufficient capacity to resist design loads. Tower structures located within alluvial floodplain terrains with weak or loose near-surface soils and with a high water table may require driven pile foundations.

Special foundations - micropiles:

This foundation type is considered a potential option for sites where it may be not be practical to maintain stable excavations in soil to construct a concrete spread footing foundations or reach bedrock, but the soil depth is too shallow for driven piles to achieve sufficient foundation lateral stability.

Transmission tower structures founded in deeper soils on Moderately Steep to Steep slopes may require micropile foundations. Micropiles are typically a small-diameter pile constructed within a drilled borehole.

4.2. Conceptual Geohazard Mitigation Structures Designs

Preliminary geotechnical comments regarding potential geohazard mitigation structures for sections along the Teigen Creek – KSM transmission line are summarized in Table C-1.

4.2.1. Snow Avalanches

Snow avalanches affecting transmission towers sites can damage towers by snow impact loading or by impact from rock or tree debris carried with the avalanche. Potential for damage depends on the potential avalanche magnitude, but also on the height of impact. The height needs to consider the accumulation of snow pack and avalanche deposits at the tower site over an appropriate design return period winter as each successive avalanche flows over the previous deposits. In addition to risks to towers, transmission lines can be affected by avalanche air blast. The clearance of transmission lines from the ground needs to consider not only accumulated late winter snowpack and avalanche deposits and debris, but also a late winter avalanche event overtop of the accumulated snow deposits encroaching on and reaching the lines.

In areas subjected to snow avalanches hazards WN Brazier proposes to use a steel monopole structure fixed atop a concrete pier with an adjacent steel deflector post facing into the direction of the avalanche path. The concrete pier height would be dependent on the magnitude of the avalanche hazard. From a geohazard mitigation perspective, the proposed snow avalanche mitigation foundation option should be a suitable solution, subject to the design considerations described above. Geotechnically, the practicality of ground anchors will depend on the site conditions. Such anchors will be practical to install on rock foundations, but less practical if the foundation consists of loose colluvial soils. Detailed design of reinforced foundations in snow avalanche hazard areas will require further analysis of avalanche design loads and geotechnical site conditions (e.g. soil or bedrock foundation characteristics at site).

For tower structures TP 14-1 to TP22-1 and TP25-1 to TP26-1, BGC (2011) identified snow avalanche paths that extend from the opposite valley side to the tower location as well as from slopes above the towers. If adjustment of the tower positions cannot be used to avoid these hazards, snow avalanche foundation design for these tower locations will need to consider snow avalanche loads from multiple directions.

4.2.2. Debris Floods / Debris Flows

Debris flows and debris floods have the potential to damage transmission tower sites through direct impact as well as by erosion of tower foundations.

Debris flow mitigation (e.g. avoidance or deflection berms) will be required upslope of tower sites where the unmitigated debris flood of debris flow risk is considered unacceptable. Tower structures TP2-2 and TP22-1 are identified by BGC (2011) as having a high unmitigated risk to a debris flow or debris hazards. Tower structures TP20-1 and TP21-2 are identified by BGC (2011) as having a moderate unmitigated risk to a debris flow or debris flow or debris flow or debris flow.

For tower structures with proposed WN Brazier snow avalanche foundations that are also exposed to debris flow or debris flood risk, it may be possible for the foundation design to mitigate against both hazards, but this would depend on additional analysis of the impact forces of both types of hazards. Similarly, detailed design of any debris flow deflection berms will require further analysis of debris flow magnitude and flow characteristics at each site.

4.3. Subsurface Investigations

No detailed subsurface investigations of soil and rock conditions, groundwater conditions, or material testing were completed as part of this work. For detailed design, subsurface investigations will be necessary to provide foundation engineers with information to:

- Select the types of foundations most suitable at each structure location.
- Determine the size and depth of the selected foundations to adequately support the transmission tower / pole structures.
- Evaluate potential problems during construction.

It is understood that the Teigen Creek Access Road would be pioneered ahead of the transmission line. As the project schedule allows, an evaluation of suitable locations for geotechnical borings and or test pits should be completed following surficial mapping of access road cuts. Soil and bedrock exposed in the construction of the access road can also be used to confirm foundation conditions at pole locations where appropriate.

5.0 **RECOMMENDATIONS FOR FURTHER WORK**

BGC recommends the following work for feasibility level design of the proposed transmission line.

Alignment Refinement:

• Review the potential to re-align the Teigen Creek access road (between KP 8.8 and KP 9.7) 10 to 15 m west allowing adjacent tower structure to maintain a greater setback from the adjacent slope crest.

- Review the potential to adjust locations of tower structures TP21-1, TP25-1 to TP27-1, TP34-1, TP35A-1, and TP40-2 as described in Table B1 to move structures onto flatter sloping terrain or further away from stream channels.
- Review access road cut slope design in conjunction with transmission line tower foundation design specifically near tower structures TP12-1 and TP34-1 and between TP23-1 to TP27-1.
- Avalanche specialist review of avalanche hazard and magnitude for pole locations for the alignment confirmed by the work above. Avalanche work should include estimate of late winter snowpack and avalanche deposits along the alignment.

Feasibility Design

With a feasibility level alignment confirmed, additional feasibility design work should include:

- Characterization of design debris flows / debris floods at tower structures TP2-2 and TP22-1 where the unmitigated risk from debris flows and debris floods is High. Develop feasibility level mitigation as required.
- Detailed analysis of avalanche design loads at tower structures TP4-2, TP6-1 to TP8-1, TP10-1, TP13-1 to TP18-1, TP20-1 to TP23-1, TP29-1, and TP30-1 where the unmitigated risks of snow avalanche hazards are considered High.
- Confirmation of tower design type(s) and height(s), foundation design loads, and foundation performance criterion for all tower structures. Use of the avalanche design loads to confirm the tower foundation design for avalanche risk areas.
- Evaluation of recommended locations for geotechnical borings and or test pits following surficial mapping of the access road during construction. Construction of the access road can also be used to confirm foundation conditions at pole locations where appropriate.
- Completion of feasibility level foundation design for the alignment that:
 - develops standard foundation designs and any necessary site specific foundation designs;
 - assigns foundation designs to tower locations; and
 - includes geohazard mitigation designs as necessary for foundation locations;

<u>Other</u>

• Update BGC's Geohazard Risk Assessment (BGC 2011) to include the current transmission line alignment. This could be included as part of any future revisions to this report.

6.0 CLOSURE

We trust the above satisfies your requirements at this time. Should you have any questions or comments, please do not hesitate to contact us.

Yours sincerely,

BGC ENGINEERING INC. per:

Greg Hunchuk, M.Eng., P.Eng., P.Geo Project Geotechnical Engineer

Reviewed by:

Mark Pritchard, M.A.Sc., P.Eng., P.Geo. Senior Geotechnical Engineer Kris Holm, M.Sc., P.Geo Senior Geoscientist and Project Manager

REFERENCES


BGC Engineering Inc. 2010. KSM Terrain Stability Field Assessment. Final Report Prepared for Seabridge Gold Inc. dated November 30, 2010.

BGC Engineering Inc. 2011. Geohazard Risk Assessment, KSM Project: TMF & Teigen Creek Access: Revision B. Final report prepared for Seabridge Gold Inc., dated August 24, 2011

APPENDIX A AVALANCHE AREA FOUNDATION TYPE AP-1

N:\BGC\Projects\0638 Seabridge\005 KSM Geohazards\05 - Reporting\Report\KSM Teigen Creek Transmission Line Prelim Geotech Assessment\20120207 KSM transmission line_preliminary geotechnical review.docx

BGC ENGINEERING INC.



GENERAL NOTES

- 1. REFER TO THE EXCEL SPREADSHEET 'STRUCTURE DATA' FOR COORDINATES OF POLE LOCATIONS, GROUND ELEVATIONS, DISTANCES **BETWEEN STRUCTURES, ETC.**
- 2. THE TRANSMISSION LINE IS DESIGNED TO, FOR THE MOST PART, TO CLOSELY FOLLOW THE ACCESS, THUS AVOIDING A SECOND RIGHT-OF-WAY, EXTENSIVE ACCESS ROADS TO TRANSMISSION LINE STRUCTURES, ETC.
- 3. TO FACILITATE CONSTRUCTION OF A 287 KV LINE ADJACENT TO THE ACCESS ROAD, STEEL (UN-GUYED) MONOPOLE CONSTRUCTION HAS BEEN SELECTED.
- 4. THE LOCATION OF DIFFICULT STRUCTURES ALONG THE ROUTE WAS SUBJECT TO EXTENSIVE GROUND TRUTHING BY GEOTECHNICAL ENGINEERS IN THE FALL OF 2011. IN THE FOLLOWING MAPPING, POLE LOCATIONS AND LINES SHOWN IN BLUE DESIGNATE THE SUBSEQUENT LINE REVISIONS.
- 5. THE TRANSMISSION LINE DESIGN, AS SHOWN ON THE PLAN DRAWINGS, IS FOR ESTIMATING AND PLANNING PURPOSES ONLY, NOT FOR TENDER OR CONSTRUCTION.
- 6. DUE TO CURRENT UNCERTAINTIES, THE LINE DESIGN HAS NOT BEEN ADVANCED TO INCLUDE PROFILE DRAWINGS.
- 7. MINIMAL TRANSMISSION LINE RIGHT-OF-WAY CLEARING IS PLANNED, ALTHOUGH THERE ARE MANY TALL "DANGER" ADJACENT TO THE PROPOSED TRANSMISSION LINE THAT WOULD HAVE TO BE REMOVED. AS THE PROPOSED LINE CLOSELY FOLLOWS THE TRACK OF THE PLANED ROAD FOR MUCH OF THE ROUTE, ADDITIONAL CLEARING WOULD GENERALLY ONLY APPLY TO ONE SIDE. AS THE RIGHT-OF-WAY WIDTH FOR A 287 KV TRANSMISSION LINE WOULD TYPICALLY BE 40 METRES, IT IS EXPECTED THAT 20 M ADDITIONAL CLEARING WOULD BE REQUIRED ON THE TRANSMISSION SIDE OF THE ROAD, BUT THIS CLEARING WOULD NOT REMOVE ALL TREES, ONLY THOSE HIGH ENOUGH TO BE A THREAT TO THE LINE WOULD BE CUT. ANNUAL CLEARING MAINTENANCE WORK WOULD BE SCHEDULED.
- 8. THE TRANSMISSION LINE ROUTE, IN CONJUNCTION WITH THE ROAD, HAS BEEN REVIEWED BY EXPERT CONSULTANTS WITH REGARDS TO GEOHAZARDS, IN PARTICULAR AVALANCHE HAZARDS.
- 9. A TYPICAL DESIGN HAS BEEN ORIGINATED FOR TRANSMISSION LINE STRUCTURES SUBJECT TO SEVERE AVALANCHE HAZARD. REFER TO THE DESIGN SKETCH. THE PRINCIPLE IS TO RAISE THE STEEL POLE BASES ABOVE THE LEVEL OF HAZARDOUS AVALANCHE FLOWS. SMALLER CONCRETE STRUCTURE FOUNDATIONS WOULD BE PROVIDED FOR POLES IN SEMI-HAZARDOUS AREAS.

- 10. THE TRANSMISSION LINE AVALANCHE HAZARD, ON A PRELIMINARY BASIS, HAS BEEN DETERMINED FROM BGC PROJECT # 0638-005 DRAWING # 10 REV. A, DEC 2010, AS PREPARED BY ALPINE SOLUTIONS, AVALANCHE SERVICES.
- 11. THE BASIC ROAD DRAWINGS, ON WHICH THE TRANSMISSION LINE ROUTE AND STRUCTURES HAVE BEEN ADDED, IS BASED ON THE MCELHANNEY TEIGEN ROAD DESIGN DRAWINGS, FALL 2010 REVISION.
- 12 THE LINE STRUCTURES HAVE BEEN LOCATED TO SUIT GROUND CONDITIONS, AS CONFIRMED IN THE FIELD, NOT TO PROVIDE LONG STRAIGHT LINE RUNS WHICH ARE OF NO IMPORTANCE WHEN USING STEEL MONO-POLES NEXT TO A ROAD. IT IS TO BE NOTED FROM THE EXCEL SPREADSHEET THAT SOME STRUCTURE LOCATIONS RESULT IN VERY SMALL LINE DEVIATIONS. EVEN THOUGH SUCH SMALL ANGLES DO NOT IMPACT STRUCTURE SELECTION AND COST, THESE LINE SEGMENTS MAY BE STRAIGHTENED AT A LATER STAGE FOR THE SAKE OF AESTHETICS, IF GROUND CONDITIONS PERMIT.

			SEABRIDGE		ELI 287
			W.N. Brazier A	ssociates Inc.	GE
			DRAWN BY: WNB CHECKED BY:	DATE: OCT. 2011 DATE:	
REV.	DATE	DESCRIPTION OF REVISION	APPROVED BY:	DATE:	210

.ECTRICAL 7 KV TRANSMISSION - TEIGEN OPTION ENERAL NOTES

RAWING NO:

621-27-E-6500 A



APPENDIX B TOWER SITE GEOLOGIC AND GEOHAZARD CHARACTERIZATION SUMMARY

N:\BGC\Projects\0638 Seabridge\005 KSM Geohazards\05 - Reporting\Report\KSM Teigen Creek Transmission Line Prelim Geotech Assessment\20120207 KSM transmission line_preliminary geotechnical review.docx

BGC ENGINEERING INC.

TABLE B-1. TOWER SITE GEOLOGIC AND GEOHAZARD CHARACTERIZATION SUMMARY FOR KSM TRANSMISSION LINE (ALIGNMENT REV. D, OCT 2011) - DRAFT

TABLE B-1.					CHARACTERIZATI	ON SUMMAR	Y FOR KS	MTRANSN	ISSION LINE	(ALIGNME		. ,		224					STRUCTURE LOC	ATION RELATIVE	1		BGC COM	MENTS
	TOWER	R ALIGNMENT	AND STRUCT					1		1	TERRA	IN UNIT, GEOL	OGY UNIT DETA	ILS ^{2,3,4}	1	1		SLOPE CLASS RANGE WITHI	TO TEIGEN ROA			FROM SI		ISIT TO KSM TRANSMISSION LINE
STRUCTURE NO.	EASTING (m)	NORTHING (m)	GROUND ELEVATION (m)	TL CHAINAGE (HORIZONTAL, APPROX.) (km)	AVALANCHE FOUNDATION (NO/YES & TYPE OF PROTECTION)	STRUCTURE NOTES	BEDROCK GEOLOGY UNIT ^{2,3}	TERRAIN SYMBOL ^{4,5}	GEOMORPHIC PROCESSES ^{4,5} (BLANK IF NONE)	DRAINAGE CLASS ^{4,5}	TERRAIN STABILITY CLASS ^{4,5}	EROSION POTENTIAL ^{4,5}	SNOW AVALANCHES	GEOHAZARD PROCESS ⁷	DIRECT CONSEQUENCE ⁷	UNMITIGATED RISK ⁷	RESIDUAL RISK ⁷	10m OF STRUCTURE ⁸	UPSLOPE (U/S) OR DOWNSLOPE (D/S OF TIEGEN ROAD	DISTANCE TO			SUGGESTED STRUCTURE LOCATION ADJUSTMENT	TOWER SITE OBSERVATIONS / COMMENTS
TP1-1	443,409	6,290,501	650	0.000	NO	3 POLE DEAD- END STRUCTURE	JBRA	Cvb		m	ш			No credible geohazards				3°-15°	N/A	N/A	Y	13-Sep-11		
TP1-2	443,266	6,290,400	610	0.175	NO	STRUCTURE	JBRA	Cvb		m				No credible geohazards				3°-15°	N/A	N/A				
TP2-1	443,079	6,290,292	575	0.391	NO		JBRA	Fp-U	U	i-p		М		No credible geohazards				0°-3°	N/A	N/A	Y	13-Sep-11		Located 25 m away from Snowbank Creek right bank. Located 40 m downslope of HWY 37.
TP2-2	442,997	6,290,100	585	0.600	NO		JBRA	Ff.Cf-Rd	Rd	m	II	М		Debris Flood	Damage to tower & service interruption		Moderate	3°-15°	D/S	180	Y	13-Sep-11		Tower is located in debris flow / debris flood fan; trees located adjacent to tower site are mature (>80 years); associated stream channel (approximately 100m away) has approximately 2 to 5 m high channel banks; there is a potential that a debris flow / flow event could lead to channel avulsion towards site. Review whether unmitigated risk would continue to be high; could consider construction of upslope diversion berm to lower geohazard risk if unmitigated risk to is considered unacceptable.
TP3-1	442,913	6,289,904	600	0.814	NO		JBRA	Ff.Cf-Rd	Rd	m	Ш	М		Debris Flood	Damage to tower & service interruption		Low	3°-15°	D/S	60	Y	13-Sep-11		Located on inactive colluvial fan feature; trees located adjacent to tower site are mature (>80 years); tower is located on raised terrain approximately 20 m elevation above the active stream channel.
TP4-1	442,881	6,289,682	600	1.037	NO		JBRA	Ff.Cf-Rd	Rd	m	П	М	A	Snow Avalanche (Size 3)	Damage to tower & service interruption		Moderate	3°-15°	D/S	30				Located on inactive colluvial fan feature; trees located adjacent to tower site are mature (>80 years); tower is located on raised terrain approximately 35 m elevation above the active stream channel. BGC (2011) identified as 'High' risk of impact from Size 3 snow avalanches; review whether avalanche protection measures are required.
TP4-2	442,940	6,289,483	608	1.245	YES AP1		JBRA	Ftu		m-i	П	м	A	Snow Avalanche (Size 3)	Damage to tower & service interruption		Moderate	3°-15° 15°-26	s ^o D/S	35				
TP5-1	442,995	6,289,298	605	1.439	NO		JBRA	Ftu		m-i	П	м		No credible geohazards				15°-26°	D/S	35				
TP6-1	443,006	6,289,086	605	1.651	YES AP1		JBRA	Cvb		w-m			A	Snow Avalanche (Size 3-4)	Damage to tower & service interruption		Moderate	3°-15°	D/S	45				Soil exposed in adjacent slope escarpment approximately 70 m to the south; tower is set back from slope escarpment
TP7-1	442,903	6,288,864	605	1.895	YES AP1		JBRA	Cvb		w-m	ш		A	Snow Avalanche (Size 3-4)	Damage to tower & service interruption	High	Moderate	3°-15° 15°-26	5° U/S	16	Y	13-Sep-11		Soil exposed in adjacent slope escarpment approximately 70 m to the east; tower is set back from slope escarpment.
TP8-1	442,813	6,288,619	627	2.156	YES AP2		JBRA	Сvb		w-m	ш			No scenarios identified				0°-3° 3°-15	• U/S	9	Y	13-Sep-11		Site is not identified in BGC (2011) as being a 'High' risk against snow avalanche. Review with snow avalanche specialist whether snow avalanche structures are necessary.
TP9-1	442,770	6,288,491	630	2.291	NO		JBRA	Cvb		w-m	ш			No scenarios identified				3°-15° 26°-35	^{5°} D/S	9				
TP10-1	442,689	6,288,273	612	2.524	YES AP2		JBRA	Cvb		w-m	111			No scenarios identified				3°-15°	D/S	33				Soil exposed in adjacent slope escarpment approximately 40 m to the south; tower is set back from slope escarpment. Considering avalanche geohazard mapping, review with snow avalanche specialist whether snow avalanche structures are necessary.
TP11-1	442,579	6,288,183	600	2.666	NO		JBRA	Cvb		w-m	ш			No scenarios identified				3°-15° 35°-45	s° U/S	51				Located adjacent to slope break; potential for shallow soils.
TP12-1	442,478	6,287,931	580	2.938	NO	3 POLE DEAD- END	JBRA	Cv//Rks		w	III			No scenarios identified				26°-35° 35°-45	° U/S	14	Y	14-Sep-11		Steeper slopes, bedrock controlled. Vertical rock bluff with associated downslope talus field located 40m southwest from tower site. Site for future geotechnical investigation.
TP13-1	442,438	6,287,477	588	3.393	YES AP1	3 POLE DEAD- END	JBRA	Cv.Mw-V		m	IV	н	А	Snow Avalanche (Size 4)	Damage to tower & service interruption		Moderate	3°-15° 15°-26	s• U/S	50				Mapped snow avalanche path travels towards site from opposite side of valley.

TABLE B-1. TOWER SITE GEOLOGIC AND GEOHAZARD CHARACTERIZATION SUMMARY FOR KSM TRANSMISSION LINE (A	
TABLE B-1. TOWER SITE GEOLOGIC AND GEORAZARD CHARACTERIZATION SUMMART FOR NSM TRANSMISSION LINE (A	ALIGNIMENT REV. D. OCT 2011) - DRAFT

					CHARACTERIZATIO								OGY UNIT DETA	ILS ^{2,3,4}				SLOPE	CLASS	STRUCTURE LOCA TO TEIGEN ROA			FROM S	BGC CON EPTEMBER 12-15TH FIELD \	IMENTS /ISIT TO KSM TRANSMISSION LINE
STRUCTURE NO.	EASTING (m)	NORTHING (m)	GROUND ELEVATION (m)	TL CHAINAGE (HORIZONTAL, APPROX.) (km)	AVALANCHE FOUNDATION (NO/YES & TYPE OF PROTECTION)	STRUCTURE NOTES	BEDROCK GEOLOGY UNIT ^{2,3}	TERRAIN SYMBOL ^{4,5}	GEOMORPHIC PROCESSES ^{4,5} (BLANK IF NONE)	DRAINAGE CLASS ^{4,5}	TERRAIN STABILITY CLASS ^{4,5}	EROSION POTENTIAL ^{4,5}	SNOW AVALANCHES	GEOHAZARD PROCESS ⁷	DIRECT CONSEQUENCE ⁷	UNMITIGATED RISK ⁷	RESIDUAL RISK ⁷	RANGE 10m STRUC	WITHIN OF	UPSLOPE (U/S) OR DOWNSLOPE (D/S) OF TIEGEN ROAD	DISTANCE TO ACCESS ROAD		DATE OF FIELD VISIT ¹	SUGGESTED STRUCTURE LOCATION ADJUSTMENT	
TP13-2	442,413	6,287,332	627	3.540	YES AP1		JBRA	Cv.Mw-V		m	IV	н	A	Snow Avalanche (Size 4)	Damage to tower & service interruption	High	Moderate	0°-3°	3°-15°	U/S	85				Mapped snow avalanche path travels towards site from opposite side of valley.
TP14-1	442,384	6,287,133	680	3.742	YES AP2		JBRA	Cv.Mw-V		m	IV	н	A	Snow Avalanche (Size 4)	Damage to tower & service interruption	High	Moderate	3°-15°	15°-26°	U/S	30				Mapped snow avalanche paths come from opposite side of valley and upslope of tower.
TP15-1	442,344	6,286,831	643	4.046	YES AP1		JBRA	Cv//Rsk		w	IV	М	A	Snow Avalanche (Size 4)	Damage to tower & service interruption	High	Moderate	0°-3°	15°-26°	U/S	38				Mapped snow avalanche paths come from opposite side of valley and upslope of tower.
TP16-1	442,213	6,286,646	643	4.273	YES AP2		JBRA	Cv//Rsk		w	IV	М	A	Snow Avalanche (Size 4)	Damage to tower & service interruption	High	Moderate	15°-26°		U/S	35				Mapped snow avalanche paths come from opposite side of valley and upslope of tower.
TP17-1	442,126	6,286,482	650	4.459	YES AP1		JBRA	Cv//Rsk		w	IV	М	A	Snow Avalanche (Size 3-4)	Damage to tower & service interruption	High	Moderate	15°-26°	35°-45°	U/S	90				Mapped snow avalanche paths come from opposite side of valley and upslope of tower.
TP18-1	441,991	6,286,382	650	4.627	YES AP1		JBRA	Cv//Rsk		w	IV	М	A	Snow Avalanche (Size 3-4)	Damage to tower & service interruption	High	Moderate	3°-15°	26°-35°	U/S	55				Mapped snow avalanche paths come from opposite side of valley and upslope of tower.
TP19-1	441,885	6,286,163	646	4.870	NO		JBRA	Cv//Rsk		w	IV	М	A	Snow Avalanche (Size 3-4)	Damage to tower & service interruption	Moderate	Moderate	0°-3°	26°-35°	U/S	55				Mapped snow avalanche paths come from opposite side of valley and upslope of tower.
					NE0 100		1004							Debris Flow	Damage to tower & service interruption	Moderate	Moderate								Mapped snow avalanche paths come from opposite side of valley and upslope of tower. Tower is located below raised hummock between
TP20-1	441,722	6,285,984	653	5.112	YES AP2		JBRA	Cf-Rd	Rd	m	II	М	A	Snow Avalanche (Size3-4)	Damage to tower & service interruption	High	Moderate	- 3°-15°	26°-35°	U/S	15	Y	14-Sep-11		(covered with mature forest) that separates avalanche paths and debris flow paths; the raised hummock is offering additional protection against upslope debris flow events.
														Debris Flow	Damage to tower & service interruption	Moderate	Moderate							Tower site is adjacent to small ephemeral creek draw;	Mapped snow avalanche paths come from opposite side of valley and upslope of tower. Tower is located below raised hummock between
TP21-1	441,593	6,285,818	633	5.322	YES AP2		JBRA	Cf-Rd	Rd	m		М	A	Snow Avalanche (Size3-4)	Damage to tower & service interruption	High	Moderate	- 3°-15°	35°-45°	U/S	16	Y	14-Sep-11	consider moving tower 15m down-chainage or up- chainage.	(covered with mature forest) that separates avalanche paths and debris flow paths; the raised hummock is offering additional protection against upslope debris flow events.
TP22-1	441,516	6,285,585	615	5.567	YES AP2		JBRA	Cf-Rd	Rd	m		м	Α	Debris Flow	Damage to tower & service interruption	High	Moderate	3°-15°	26°-35°	U/S	21				Mapped snow avalanche paths come from opposite side of valley and upslope of tower; tower is located at the margins of the debris flow path and snow avalanche path immediately adjacent to the forested terrain.
	441,010	0,200,000	010	0.007			UDION	of Ru						Snow Avalanche (Size3-4)	Damage to tower & service interruption	High	Moderate	0 10	20 00	0,0	2.				Increase embedment of reinforced tower foundation and construction of a deflection berm / should be considered for increased protection against active upslope debris flows.
TP23-1	441,388	6,285,424	610	5.773	YES AP2		JBRA	Fp-U	U	i-p	I	М	A	Snow Avalanche (Size 3-4)	Damage to tower & service interruption	High	Moderate	15°-26°	26°-35°	U/S	14				Tower site is located on lower slopes, away from adjacent floodplain. Mapped snow avalanche path travels towards site from
																									opposite side of valley. Mapped snow avalanche paths come from opposite side
TP24-1	441,300	6,285,270	628	5.951	NO		JBRA	Cvb		m	Ш	М	A	Snow Avalanche (Size 3-4)	Damage to tower & service interruption	High	Moderate	15°-26°	35°-45°	U/S	13	Y	14-Sep-11		of valley and upslope of tower. BGC (2011) identified as 'High' risk of impact from Size 3- 4 snow avalanches; review whether avalanche protection measures are required.
																								Alternate option to	Steep soil slopes anticipated; for tower foundation stability, structures may require a retaining wall else require special foundation types such as micro-piles or soil/rock anchors.
TP25-1	441,149	6,285,084	604	6.190	NO		JBRA	Cvb		m	ш	М	А	Snow Avalanche (Size 3-4)	Damage to tower & service interruption	High	Moderate	26°-35°	35°-45°	U/S	4	Y	14-Sep-11	1, and TP27-1 is to locate	Site for future geotechnical investigation.
														(5128 3-4)										towers locate 80 m upslope (east) from present alignment	of valley and upslope of tower.
														Snow	Demons is town of										BGC (2011) identified as 'High' risk of impact from Size 3- 4 snow avalanches; review whether avalanche protection measures are required.
TP26-1	441,146	6,284,918	620	6.357	NO		JBRA	Ckv		w-m	III	М	A	Avalanche (Size 3-4)	Damage to tower & service interruption	High	Moderate	35°-45°		U/S	14			Refer to TP25-1 comment	Refer to TP25-1 comment

TABLE B-1. TOWER SITE GEOLOGIC AND GEOHAZARD CHARACTERIZATION SUMMARY FOR KSM TRANSMISSION LINE (ALIGNMENT REV. D, OCT 2011) - DRAFT

	TOWER		AND STRUCT	URE DETAILS FF	ROM WN BRAZIER ¹						TERRA	IN UNIT, GEOLO	OGY UNIT DETAI	LS ^{2,3,4}				SLOPE	E CLASS	STRUCTURE LOCA TO TEIGEN ROAD		
STRUCTURE NO.	EASTING (m)	NORTHING (m)	GROUND ELEVATION (m)	TL CHAINAGE (HORIZONTAL, APPROX.) (km)	AVALANCHE FOUNDATION (NO/YES & TYPE OF PROTECTION)	STRUCTURE NOTES	BEDROCK GEOLOGY UNIT ^{2,3}	TERRAIN SYMBOL ^{4,5}	GEOMORPHIC PROCESSES ^{4,5} (BLANK IF NONE)	DRAINAGE CLASS ^{4,5}	TERRAIN STABILITY CLASS ^{4,5}	EROSION POTENTIAL ^{4,5}	SNOW AVALANCHES⁵	GEOHAZARD PROCESS ⁷	DIRECT CONSEQUENCE ⁷	UNMITIGATED RISK ⁷	RESIDUAL RISK ⁷	RANGE 10r		UPSLOPE (U/S) OR DOWNSLOPE (D/S) OF TIEGEN ROAD	DISTANCE TO	FIELD VI Y/N
TP27-1	441,231	6,284,742	620	6.552	NO		JBRA	Ckv		w-m	Ш	М	A	Snow Avalanche (Size 3-4)	Damage to tower & service interruption		Moderate	35°-45°		U/S	7	
TP28-1	441,322	6,284,606	660	6.715	NO		JBRA	Ckv		w-m	ш	м		No scenarios identified				26°-35°		U/S	18	
TP29-1	441,341	6,284,455	665	6.867	YES AP2		JBRA	Ckv		w-m	ш	м	A	Snow Avalanche (Size 3-4)	Damage to tower & service interruption		Moderate	15°-26°	26°-35°	U/S	18	Y
TP30-1	441,287	6,284,227	683	7.102	YES AP2		JBRA	Ckv		w-m	ш	м	А	Snow Avalanche (Size 3-4)	Damage to tower & service interruption		Moderate	3°-15°	26°-35°	U/S	48	Y
TP31-1	441,192	6,284,040	690	7.311	NO		JBRA	Ckv		w-m	ш	М		No scenarios identified				3°-15°	15°-26°	U/S	49	
TP32-1	441,099	6,283,843	697	7.529	NO		JBRA	Cv/Mw		w-m	IV			No scenarios identified				3°-15°	15°-26°	U/S	56	
TP33-1	441,062	6,283,608	707	7.767	NO		JBRA	Ckv		w	ш	М		No scenarios identified				3°-15°	15°-26°	U/S	45	
TP34-1	441,004	6,283,354	650	8.028	NO		JBRA	Fp-U		i-p	1	М		No scenarios identified				3°-15°	26°-35°	D/S	29	
TP35-1	440,832	6,283,167	700	8.282	NO		JBRA	Cv//Rks-V		w	IV	н		No scenarios identified				3°-15°	15°-26°	D/S	30	Y
TP35-2	440,843	6,282,983	750	8.467	NO		JBRA	Mw Ru		m	П	L		No scenarios identified				0°-3°	3°-15°	D/S	2	Y
TP35-3	440,853	6,282,811	755	8.639	NO		JBRA	Mw Ru		m	П	L		No scenarios identified				0°-3°	3°-15°	D/S	6	Y
TP35A-1	440,866	6,282,640	761	8.810	NO		JBRA	Mw Ru		m	II	L		No scenarios identified				0°-3°	26°-35°	D/S	37	
TP35A-2	440,851	6,282,455		8.995	NO		JBRA	Cv//Rks-V		w	IV	н		No scenarios identified				3°-15°	15°-26°	D/S	32	
TP36-1	440,838	6,282,275	773	8.995	NO		JBRA	Mw Ru		m	П	L		No scenarios identified				3°-15°	15°-26°	D/S	22	Y
TP36-2	440,717	6,282,077	812	9.227	NO		JBRA	Mw Ru		m	П	L		No scenarios identified				3°-15°		U/S	55	Y
TP36-3	440,594	6,281,879	840	9.460	NO		JBRA	Mw Ru		m	П	L		No scenarios identified				3°-15°		U/S	170	Y
TP37-1	440,470	6,281,677	852	9.697	NO		JBRA	Mb		m	П	L		No scenarios identified				3°-15°	15°-26°	D/S	17	Y
TP38-1	440,402	6,281,442	867	9.942	NO		JBRA	Cv//Rks-V		w	IV	н		No scenarios identified				3°-15°	15°-26°	D/S	15	Y

	FROM SE	BGC COM PTEMBER 12-15TH FIELD V	MENTS ISIT TO KSM TRANSMISSION LINE
VISIT ¹⁰ //N	DATE OF FIELD VISIT ¹⁰	SUGGESTED STRUCTURE LOCATION ADJUSTMENT	TOWER SITE OBSERVATIONS / COMMENTS
		Refer to TP25-1 comment	Steep soil slopes anticipated; for tower foundation stability, structures may require a retaining wall else require special foundation types such as micro-piles or soil/rock anchors. Site for future geotechnical investigation. Mapped snow avalanche path travels towards site from opposite side of valley.
Y	14-Sep-11		
Y	14-Sep-11		
		Consider moving towards hillslope (east) and founding on bedrock if present and suitable.	Debris flow channel is located approximately 100m upstream from tower location; site could experience periodic flooding associated with debris flow/flood events. Site for future geotechnical investigation; potentially may require special foundations (driven piles).
Y	12-Sep-11		
Y	12-Sep-11		
Y	12-Sep-11		
		Tower site is located immediate to slope break; consider moving tower 10m east towards access road.	
Y	12-Sep-11		Tower site is located 20m away from slope break. Soil exposed in escarpment face ~80m to the east on slope escarpment

					CHARACTERIZATIO	UN SUMMAR	T FUR NS	W TRANSIN	1155ION LINE									1	STRUCTURE LOC	ATION RELATIVE	1		BGC COM	MENTS
	TOWER	R ALIGNMEN	FAND STRUC	TURE DETAILS FI	ROM WN BRAZIER ¹						TERRA	IN UNIT, GEOL	OGY UNIT DETAI	LS ^{2,3,4}				SLOPE CLASS	TO TEIGEN ROA			FROM SI		ISIT TO KSM TRANSMISSION LINE
STRUCTURE NO.	EASTING (m)	NORTHING (m)	GROUND ELEVATION (m)	TL CHAINAGE (HORIZONTAL, APPROX.) (km)	AVALANCHE FOUNDATION (NO/YES & TYPE OF PROTECTION)	STRUCTURE NOTES	BEDROCK GEOLOGY UNIT ^{2,3}	TERRAIN SYMBOL ^{4,5}	GEOMORPHIC PROCESSES ^{4,5} (BLANK IF NONE)	DRAMAGE	TERRAIN STABILITY CLASS ^{4,5}	EROSION POTENTIAL ^{4,5}	SNOW AVALANCHES ⁶	GEOHAZARD PROCESS ⁷	D DIRECT CONSEQUENCE	UNMITIGATED	RESIDUAL RISK ⁷	RANGE WITHIN 10m OF STRUCTURE ⁸	UPSLOPE (U/S) OF) DISTANCE TO	FIELD VISIT ¹⁰ Y/N	DATE OF FIELD VISIT ¹⁰	SUGGESTED STRUCTURE LOCATION ADJUSTMENT	TOWER SITE OBSERVATIONS / COMMENTS
TP39-1	440,295	6,281,216	885	10.192	NO		JBRA	Cv//Rks-V		w	IV	н		No scenarios identified				15°-26°	D/S	20	Y	12-Sep-11		
TP40-1	440,224	6,280,984	897	10.435	NO		JBRA	Mw Ru		w	Ш	L		No scenarios identified				3°-15°	D/S	16				
TP40-2	440,182	6,280,776	880	10.647	NO		JBRA	Cv//Rks-V		w	IV	н		No scenarios identified				26°-35° 35°-45	D/S	140			Consider moving tower 20m west to keep tower away from moderately steep to steep slopes.	
TP40-3	440,143	6,280,566	885	10.860	NO		JBRA	Cv//Rks-V		w	IV	н		No scenarios identified				15°-26° <mark>26°-35</mark>	• N/A	-				
TP40-4	440,102	6,280,357	920	11.074	NO		JBRA	Cv/Mw		w	Ш			No scenarios identified				15°-26° <mark>26°-35</mark>	• N/A	-				
TP40-5	440,061	6,280,147	980	11.287	NO		JBRA	Cv/Mw		w	II			No scenarios identified				15°-26° 26°-35	° N/A	-				
TP40-6	440,021	6,279,938	1035	11.500	NO		JBRA	Cv/Mw		w	П			No scenarios identified				15°-26°	N/A	-				
TP40-7	439,977	6,279,715		11.727			JBRA	Mw Rm/Rm		w-m	п	L		No scenarios identified				3°-15° 15°-26	• N/A	-	Y	13-Sep-11		
TP41-1	439,955	6,279,600	1080	11.727		3 POLE DEAD- END, (Last Structure Before Substation)	JBRA	Mw Rm/Rm		w-m	П	L		No scenarios identified				3°-15°	N/A	-	Y	13-Sep-11		
TP42-1	439,993	6,279,534	1070	0.000		SUBSTATION NO. 1 STRUCTURE (In Substation Yard)	JBRA	Mw Rm/Rm		w-m	11	L		No scenarios identified				3°-15° 15°-26	• N/A	-	Y	13-Sep-11		

TABLE B-1. TOWER SITE GEOLOGIC AND GEOHAZARD CHARACTERIZATION SUMMARY FOR KSM TRANSMISSION LINE (ALIGNMENT REV. D. OCT 2011) - DRAFT

NOTES:

1. Transmission line alignment details from WN Brazier, KSM Excel Structure Data Rev D. dated October 24, 2011

2. Data Source: Regional Location and Generalized Geology Map from BGC (2011), Figure 1-1

3. JBRA: Bowser Lake Group, Mesozoic - Sandstone, Siltstone, Rare Conglomerate

4. Data Source: Teigen Access Road Terrain Map and Landslide Geohazards from BGC (2011), Drawing 03

5. See Drawing 01 for a Description of Terrain Symbols.

6. Data Source: Teigen Access Road Avalanche Geohazards from BGC (2011), Drawing 04

7. Data Source: Snowbank Creek Switching Station and Transmission Line Risk Assessment from BGC (2011), Table B-3

8. Slope Classes determined from 2009 LiDAR Topography and Geobase DEM

9. Teigen Access Road alignment from McElhanney, Nov 2, 2010 road alignment

10. Field visit considering transmission line alignment from WN Brazier, KSM Excel Structure Data Rev 2. Dated September 2, 2011

APPENDIX C PRELIMINARY GEOTECHNICAL COMMENTS

N:\BGC\Projects\0638 Seabridge\005 KSM Geohazards\05 - Reporting\Report\KSM Teigen Creek Transmission Line Prelim Geotech Assessment\20120207 KSM transmission line_preliminary geotechnical review.docx

BGC ENGINEERING INC.

TABLE C-1. SUMMARY OF PRELIMINARY GEOTECHICAL COMMENTS FOR KSM TRANSMISSION LINE (ALIGNMENT REV. D, OCT 2011) - DRAFT

SECTION		STRUCT	URE ID	NUMBER	CHAINA				ANTICIPATED		STRUCTURE PROXIMITY TO	
ID	SECTION	FROM	то	STRUCTURES	FROM	то	TERRAIN DESCRIPTION	SLOPE CLASS ¹	SUBSURFACE CONDITIONS	RECOGNIZED GEOHAZARDS	ACCESS ROAD	GEOTECHNICAL COMMENTS ²
А	Southwest facing slope upslope of HWY 37	TP1-1	TP-1-2	2	0	0.175	Colluvial blanket, gentle slope	Gentle slopes	Soils >3m deep; moderate to poor drainage		Away from HWY 37 and access road.	Spread footing / drilled pier foundations
В	HWY 37 Crossing between TP2-1 and TP2-2	TP2-1	-	1	0.391	-	Fluvial floodplain, flat slope		Soils >3m deep, low bearing near surface soils, imperfect to poor drainage - high water table	Flooding	Downslope 40m from raised road- fill section of HWY 37.	Special foundation: driven piles.
С	Near Snowbank Creek - Teigen Creek Junction	TP2-2	-	1	0.599	-	Fluvial fan / colluvial fan, gentle slope		Soils >3m deep, moderate drainage, potentially higher water table	Debris flood: unconfined creek channel is located upslope of tower site; debris flood potential.	Downslope 180m from Teigen	Spread footing / drilled pier foundations Construction of upslope debris flow deflection berm if unmitigated risk to is considered unacceptable.
										Snow avalanches	Downslope 30 to 50 m from Teigen access road.	Spread footing / drilled pier foundations
D	West of Teigen Creek	TP3-1	TP6-1	5	0.814	1.650	Glaciofluvial terrace, gentle to moderate slopes	Gentle to Moderate slopes	Soils >3m deep, moderate drainage	Located above active debris flood terrain		Review whether special snow avalanche foundations are required for TP4-1
E	West of Teigen Creek	TP7-1	TP10-1	4	1.895	2.525	Glaciofluvial terrace to colluvial blanket, gentle to moderate slopes	Gentle to Moderate slopes	Soils >3m deep, moderate to well drained	Snow avalanches	Upslope 10 to 20m from Teigen access road.	Spread footing / drilled pier foundations Review whether special snow avalanche foundations are required for TP8-1 and TP10-1
F	West of Teigen Creek	TP11-1	-	1	2.666	-	Glaciofluvial to colluvial veneer over bedrock, gentle slopes adjacent to steep slopes immediately upslope		Soils 1-3m deep, moderate drainage			Dependent upon depth of soil: potentially soil or rock foundations
G	West of Teigen Creek	TP12-1	-	1	2.937	-	Colluvial veneer over bedrock, steep slope	Steep slopes	Bedrock near surface, soils <1m deep.		road.	Rock foundation Integrate access road and tower alignment design associated with with steep natural slopes and proximity of adjacent road cut
н	Teigen Creek crossing between TP12-1 and TP13- 1	TP13-1	14-1	3	3.393	3.741	Terrace, gentle to moderate slope	Gentle to Moderate slopes	Soils >3m deep, moderate drainage	Snow avalanches paths from slopes above and from opposite side of valley	Upslope 30 to 85m from Teigen access road.	Spread footing / drilled pier foundations Review whether special snow avalanche foundations should consider snow avalanche paths that extend from the opposite valley side to the tower location as well as from slopes above the tower
I	East of Teigen Creek	TP15-1	TP18-1	4	4.046	4.626	Colluvial veneer over bedrock with some narrow benches, moderate to steep slope	Moderate to Steep slopes	Soils 1-3m deep, moderately drained	Snow avalanches paths from slopes above and from opposite side of valley	Upslope 35 to 90m from Teigen access road.	Dependent upon depth of soil overburden: potentially soil or rock foundations Review whether special snow avalanche foundations should consider snow avalanche paths that extend from the opposite valley side to the tower location as well as from slopes above the tower
J	East of Teigen Creek	TP19-1	-	1	4.870	-	Terrace, flat to gentle slope	Gentie sinnes	Soils >3m deep, moderate to well drained		Upslope 55m from Teigen access road.	Spread footing / drilled pier foundations

TABLE C-1. SUMMARY OF PRELIMINARY GEOTECHICAL COMMENTS FOR KSM TRANSMISSION LINE (ALIGNMENT REV. D, OCT 2011) - DRAFT

SECTION			TURE ID	NUMBER		GE (KM)		•	ANTICIPATED		STRUCTURE PROXIMITY TO	
ID	SECTION	FROM	то	STRUCTURES IN SECTION	FROM	то	TERRAIN DESCRIPTION	SLOPE CLASS ¹	SUBSURFACE CONDITIONS	RECOGNIZED GEOHAZARDS	ACCESS ROAD	GEOTECHNICAL COMMENTS ²
к	East of Teigen Creek	TP20-1	TP21-1	2	5.112	5.322	Colluvial fan, gentle to moderate slope			Snow avalanches / debris flows located within section Snow avalanches paths form from slopes above and from opposite side of valley Tower sites are generally located behind raised hummocks with mature forest cover; hummocks are offering additional protection against debris flows.	Upslope 15 to 20m from Teigen access road.	Spread footing / drilled pier foundations Review whether special snow avalanche foundations should consider snow avalanche paths that extend from the opposite valley side to the tower location as well as from slopes above the tower
L	East of Teigen Creek	TP22-1	-	1	5.567		Colluvial fan, gentle to moderate slope	Gentle to Moderate slopes	Soils >3m deep, moderate to well drained	Snow avalanches / debris flows located within section Snow avalanches paths form from slopes above and from opposite side of valley Tower site is located within immature forest and adjacent to mature forest; site may not be protected against debris flows.	Upslope 15 to 20m from Teigen access road.	Spread footing / drilled pier foundations Construction of upslope debris flow deflection berm to protect against debris flow scour Review whether special snow avalanche foundations should consider snow avalanche paths that extend from the opposite valley side to the tower location as well as from slopes above the tower
М	East of Teigen Creek	TP23-1	TP24-1	2	5.773	5.951	Terrace escarpment, moderate to steep slope		Soils >3m deep, moderate to well drained	Snow avalanches paths form from slopes above and from opposite side of valley	Upslope 15m from Teigen access road.	Spread footing / drilled pier foundations Review whether special snow avalanche foundations are required for TP24-1 Integrate access road and tower alignment design associated with with steep natural slopes and proximity of adjacent road cut.
N	East of Teigen Creek	TP25-1	TP27-1	3	6.190	6.552		Moderarately Steep to Steep slopes		Snow avalanches, form above TP25- 1 and from opposite side of valley from TP25-1, TP26-1, and TP27-1.	Upslope 5 to 15m from Teigen access road.	Special foundations: micro-piles or soil anchors likely necessary associated with steep natural slopes and close proximity of Teigen Creek access road. Review whether special snow avalanche foundations are required for TP25-1 and TP26-1 Integrate access road and tower alignment design. Consider relocating transmission line alignment on terrace located 80m upslope to avoid construction of special foundations on steep slopes.
0	East of Teigen Creek	TP28-1	TP29-1	2	6.715	6.867	Colluvial veneer to blanket, moderate to moderately steep slope	Moderate to Moderately Steep slopes	Soils 1-3m deep, moderate to well drained.	Snow avalanche path upslope of TP29-1	Upslope 20m from Teigen access road.	Dependent upon depth of soil overburden: potentially soil or rock foundations Integrate access road and tower alignment design associated with with steep natural slopes and proximity of adjacent road cut.
Р	East of Teigen Creek	TP30-1	TP33-1	4	7.102	7.767	Terrace - flat to gentle slope	Plain to Gentle slopes	Soils >3m deep, moderate to well drained	Snow avalanche path upslope of TP30-1	Upslope to 50m from Teigen access road.	Spread footing / drilled pier foundations

TABLE C-1. SUMMARY OF PRELIMINARY GEOTECHICAL COMMENTS FOR KSM TRANSMISSION LINE (ALIGNMENT REV. D, OCT 2011) - DRAFT

SECTION		STRUCT	TURE ID	NUMBER	CHAINA	GE (KM)			ANTICIPATED		STRUCTURE PROXIMITY TO	
ID	SECTION	FROM	то	STRUCTURES IN SECTION	FROM	то	TERRAIN DESCRIPTION	SLOPE CLASS ¹	SUBSURFACE CONDITIONS	RECOGNIZED GEOHAZARDS	ACCESS ROAD	GEOTECHNICAL COMMENTS ²
	Teigen Creek crossing between TP34-1 and TP35- 1; Near Seabee Camp	TP34-1		1	8.028		Floodplain, flat adjacent to steep slope escarpment	Plain slope immediately adjacent to Steep slope escarpment	Soils >3m deep, low bearing near surface soils, imperfect to poor drainage - high water table	Flooding Debris flow path located 100m upstream and in combination with raised access road crossing, could increase potential for flooding downstream	Upstream on floodplain 30m from Teigen access road	Special foundation: driven piles, else consider constructing tower closer to adjacent slope escarpment Integrate access road and tower alignment design.
R	West of Teigen Creek	TP35-1	TP36-1	6	8.282	8.995	Till plain adjacent to slope escarpment, flat to moderate slope	Plain to Moderate slopes	Soils 1-3m deep, moderate drainage.			Dependent upon depth of soil overburden: potentially soil or rock foundations.
S	West of Teigen Creek	TP36-2	TP36-3	2	9.227	9.460	Till plain, gentle slope	Gentle slopes	Soils 1-3m deep, moderate drainage.			Dependent upon depth of soil overburden: potentially soil or rock foundations
т	West of Teigen Creek	TP37-1	TP40-2	5	9.697	10.647	Till plain adjacent to slope escarpment, gentle to moderate slope	Gentle to Moderate slopes	Soils <1m deep, moderate to well drained.		Downslope 15 to 20m from Teigen access road. Review location of access road drainage structures with respect to tower locations	Dependent upon depth of soil overburden: potentially soil or rock foundations
U	West of Teigen Creek	TP40-3	TP40-6	4	10.860	11.500	Till veneer to blanket, moderate to moderately steep slope	Moderate to Moderately Steep slopes	Soils <1m deep, well drained.			Dependent upon depth of soil overburden, anticipate rock foundations
V	Near KSM Plant Site	TP40-7	TP42-1	3	11.727		Bedrock plateau, flat to gentle slope	Plain to Gentle slopes	Bedrock at ground surface; adjacent low-lying depression sites with peaty organics		Away from Teigen access road	Rock foundations

NOTES:

1. Slope Classes:

- Plain slope: 0-3° (0-5%)

- Gentle slope: 3-15° (6-26%)

- Moderate slope: 15-26° (27-49%)

- Moderately Steep slope: 26-35° (50-70%)

- Steep slope: 35-45° (71-100%)

- Very Steep slope: >45° (>100%)

2. No detailed investigation of subsurface soil, rock, and groundwater conditions has been carried out. Terrain conditions and geotechnical comments are preliminary. Foundation conditions should be further evaluted through subsurface investigations with results incorporated into design.

DRAWINGS

N:\BGC\Projects\0638 Seabridge\005 KSM Geohazards\05 - Reporting\Report\KSM Teigen Creek Transmission Line Prelim Geotech Assessment\20120207 KSM transmission line_preliminary geotechnical review.docx

BGC ENGINEERING INC.

8	430000 	432500	435000 I	437500 I	440000 I	442500 I	445000 I
62925	LEGEND	POLYGON LABELS Terrain symbol Cv/Rs – R"b	Drainage	N			1500 1600
	PROPOSED TRANSMISSION LINE	TERRAIN SYMBOLS	r Rapid w Well m Moderate i Imperfect p Poor vp Very Poor	4			1400-
	TRANSMISSION LINE STRUCTURES	Simple Terrain Symbols: Used when one surficial material is present within a polygon Example: Cb – Rb I I	Surface Erosion Potential (Assigned to polygons intersecting proposed access roads)VLVery low potential - Flat or gently sloping terrain, organic soils, floodplai n			1010 Cc-ARd m II U	
	Debris Flow (Rd, Rsd)	Surficial Material Geomorphological process sub-type Surface expression Geomorphological process (up to 3 may be assigned) <u>Composite Terrain Symbols:</u> Used when 2 or 3 terrain types are present within a polygon	L Low potential - Gentle slopes, short slopes M Moderate potential - Moderate steep slopes and long slopes; erodible (fine -textured) soi H High potential - Moderate steep slopes and highly erodible soil textures VH Very high potential - Steep slopes with erodible soil textures, active surface/gully erosior	1994 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994 -	3		
	Debris Avalanche (Rs)	Cv.Mvindicates that 'C' and 'M' are roughly equal in extentCv/Mvindicates that 'C' is greater in extent than 'M' (about 60:40)Cv/Mvindicates that 'C' is much greater in extent than 'M' (about 80:20)	Terrain Stability Class (Assigned to polygons intersecting proposed roads and fixed facilities)	St. Mar			
	Rockfall (Rb)	<u>Stratigraphic Terrain Symbols</u> Cv/Mj indicates that 'Cv' overlies 'Mj'	 No significant stability problems exist. There is a very low likelihood of landslides following road constructi on. Minor slumping is expected along road cuts, especially for 1 or 2 years following construction. There is a low likelihood of landslide initiation following road construction. Minor slumping 	and the second second		1012 Cvb-ARd w-m W W W W W W W W W W W W W	
	Slope Sagging (Fm)	/Cv Mj indicates that 'Cv' partially overlies 'Mj' Surficial Material Types	is expected along road cuts, especially for 1 or 2 years following construction. IV Expected to contain areas with a moderate likelihood of landslide initiation following road construction.		Cv.	1013 Rsk-ARd W 1011)	
	Rock Avalanche (Rr)	C Colluvium R Bedrock LG Glaciolacustrine L Lacustrine M Glacial Till FG Glaciofluvial F Fluvial O Organic	V Expected to contain areas with a high likelihood of landslide initiation following road construction.			₩ 33 5 Ca m II II II II II II II II II II II II I	TP141
	Rock Slump (Rm)	Surface Expressions	NOTES: 1. This map should be read with the accompanying report and the	Contraction of		TP1	
0000	Rockfall and Debris Flow or Debris Avalanche (Rbd, Rbs)	pPlain (0-3°)vVeneer (0-2 m thick deposit)jGentle Slope (4-14°)bBlanket (>2 m thick deposit)aModerate Slope (15-26°)wVariable Thickness Deposit)kModerately Steep Slope (27-35°)mRolling	BGC report "KSM Project Geohazard and Risk Assessment Tailings Management Facility and Teigen Creek Access, Revision B", dated August 24, 2011.	The Contraction		BOD	
629(> LANDSLIDE PATH	s Steep Slope (>35°) h Hummocky c Cone (>15°) f Fan (<15°) r Ridge u Undulating t Terrace	 Facilities are all proposed, not existing. General arrangements provided by KCBL on June 14, 2011. Referenced files: 	Stratter Const		TP3-1	HIGHWAY/37
		<u>Geomorphologic Processes</u> R Rapid landslide (runout zone) V Gully erosion	 I-KCBL-MAY2011.dwg I-BY-OTHERS-MAY2011.dwg Transmission Line Alignment provided by WN Brazier on Oct.24, 2011. 			5 CPTP4-1 6 Ftt mt	
	SACKUNG	R* Rapid landslide (initiation zone) F* Slow landslide (initiation zone) U Flooding Geomorphological Process Subtypes (May be Combined)	 KSM Excel Structure Data Rev D.xls 5. Small magnitude geohazards exist (e.g. localized rockfall) 		NUL STREET & COMPANY	Öv III Öv III III III	
	TERRAIN POLYGON	b Rockfall r Rock slides (Rr, R"r) c Soil creep d Debris flows s Debris avalanches m Slump e Earthflow	that were too small to map. 6. Landslide paths show general slide trajectories, not extent of hazard. 7. This map is a snapshot in time. Changes in land use (e.g. development, glacial retreat) may warrant re-drawing of certain areas.			Cv.Rks W 2 2 2 2 2 2 2 2 2 2 2 3 3 3 3 4 4 7 7 6-1	
	(NUMBERED) R" Rapid Landslide (Initiation Zone) R Rapid Landslide (Runout Zone) F" Slow Landslide (Initiation Zone) F Slow Landslide (Runout Zone)	Examples /Cv Mb Partial cover of a Colluvial Veneer over a till blanket Rs//Cv – VR"bd Steep bedrock with <20% cover of a colluvial veneer; gullied with initiation zones for rockfall and debris flows.			1500 CV/R V	Its=V It CV/IXX CVD V V W W V W W W <	22 Mby mw
					1000 1700 1700 1700 13 Rs/Cv-R"b V V 24 CV/Rs-V V V 24 CV/Rs-V V V	W 8 16 V.R.s-V V.R.s-V 17 W W V V.R.s-V W V.R.s-V V V.R.s-V	
87500					w Cv/Rak 25 Cv/Rs-V 28	State	23 Mwb
62						Cab H W m TTP13:2	
					CV/Rs-R"s Cvb.Rk W W 29 Cvb	37 Cf-Rd TP14-1 MW/Rah	SION LINE 1100
					as 31 W'm	W-m	43 1200

